

# Clusters of Flexible PV-Wind-Storage Hybrid Generation (FlexPower)

## Topic Area 6: Generation Subtopic 1: Hybrid Systems


### Project Summary

NREL – INL - SNL project team

May 26, 2022

# General FlexPower Concept

*The main research objective of this project is to provide the industry with an answer and a solution to the following question: How can hybrid plants consisting of renewable energy and storage be transformed into fully dispatchable and flexible sources of energy suited to operate in day-ahead and real-time energy markets as well as flexibility and capacity services markets while providing all essential reliability and resiliency services to the bulk power system?*




**Main tasks:**

- Hybridization potential evaluation (wind, solar and hydro power/PSH)
- Plant controls development and demonstration (wind, solar, hydro, storage)
  - PSH, H2 storage, BESS, kinetic, UCAP
  - Fast and slow controls
  - Resiliency services
- Regional integrations study




**Project team: NREL, INL, SNL**

# Energy Storage in FlexPower




# Hybridization Potential Evaluation

- Generated maps comparing complementarity with pumped storage hydropower resource assessment (top figures)
- Completed draft journal article covering wind-PV complementarity analysis, which:
  - **Wide range of metrics for wind-PV complementarity**, based on **hourly** generation profiles derived across multiple **weather years**
  - Price-taker analysis exploring the relationship between **complementarity and energy value**, now and in the future
  - Draft to WETO: end of Q2




Comparing wind capacity factor and stability benefits of hybridization



# Seasonal variation in hourly correlated PV-Wind power production




Monthly Pearson




# FlexPower Control functions

- Dispatchable energy services and flexibility services with resource forecast:
  - Reduced curtailment, increased energy production, and higher capacity factors from the same plant footprints
  - Fully dispatchable, load-following operation using long (hours, days)- and short-term (5 min) production forecasts, and capability to bid into day-ahead and real-time energy markets (like conventional generation), forecast error mitigation
  - Capacity and flexibility services
  - Aggregate plant level ramp limiting, variability smoothing, and cloud and wake impacts mitigations
  - Various strategies to provide different types of reserve and flexibility products (head room estimation for wind and solar is implemented)
- Essential and advanced reliability services:
  - Automatic generation control (AGC) and primary frequency response
  - Fast frequency response (FFR) and synthetic inertia
  - Superior plant-level 4-quadrant dynamic reactive power/voltage control
  - Stable operation with weaker grids
  - Enhanced fault ride-through performance/recovery profiles, programmable reactive current injection
  - Advanced controls for damping all types of power system oscillations, control interactions, and resonances
- Transient performance
- Resiliency services:
  - Grid-forming, black start, participation in grid restoration
  - Islanded operation



# FLEXPOWER “MARKET INTERFACE”


## The two-layer FlexPower Plant Controller



**NREL-SIIP**  
**Regional Integration Study**

- Features of the scheduling layer**  
Scheduling layer or Market interface
- Does not try to predict prices
  - Accounts for potential forecast error
  - Assumes ISO-management of energy constraints

# Timeline of FLEXPOWER “MARKET INTERFACE”







# Hybrid wind-PV-storage plant model – 300-day simulation







100 MW wind

90 MW PV


100 MW / 4 hr storage




# Real-time 5-min dispatch – example days






# FlexPower Hybrid Plant Demonstration Platform




Imbedded in ARIES platform



- Additional assets:
- 20 MW CGI (2021)




# Multi-task Controller Interface




# Test platform




300 MVA Adjustable speed pump storage  
hydro unit  
3000 MW.h




50 MVA Fixed speed pump storage  
hydro unit  
500 MW.h




50 MVA Hydrogen storage  
5 MW.h




# H2 Storage Model Integrated in PHIL



# Flexpower Plant in IEEE 39 Bus System



## FPP: Flexpower Plant control panel




# FlexPower Controller







# Wind / PV / H<sub>2</sub> Storage plant operation at Flatirons Campus




# Wind / PV / H<sub>2</sub> Storage plant operation at Flatirons Campus




# PSCAD Model of FlexPower Plant – all components



# H<sub>2</sub> storage RT model integrated in FlexPower Test Platform




# RTDS-Typhoon HIL Interfacing and FlexPower H2 CHIL




- Tested CHIL with RTDS (IEEE39 bus) EPC HIL Connect and HIL 604.

# RTDS-Typhoon HIL and HILConnect Integration


## Setup at NREL ARIES for H2 Electrolyzer and Fuel Cell System CHIL



**Typhoon HIL Emulator  
+ EPC Connect**



**Typhoon HIL  
Interface Board**






**RTDS  
RSCAD**


Power command:  
0 to +500kW  
(Fuel Cell Gen.)

Ramp rate (true):  
4 MW/s


Vrms at PCC:  
< 1.05 per unit





# IEEE39 bus model + Flexpower



Added Typhoon CHIL node




# H2 Storage Operation in IEEE39 bs system – PHIL setup





# Northern CA Test System: Integration Study for FlexPower Plants

## Norcal Test System Capacity Mix



```
julia> norcal_sys
System
```

Property	Value
System Units Base	SYSTEM_BASE
Base Power	100.0
Base Frequency	60.0
Num Components	8035

### Static Components

Type	Count	Has Static Time Series	Has Forecasts
Arc	2413	false	false
Area	4	true	true
Bus	1969	false	false
GenericBattery	5	false	false
HydroDispatch	232	true	true
Line	1463	false	false
LoadZone	4	false	false
MonitoredLine	344	false	false
PowerLoad	658	true	true
RenewableDispatch	60	true	true
ThermalStandard	153	false	false
Transformer2W	730	false	false

### Time Series Summary

Property	Value
Components with time series data	950
Total StaticTimeSeries	1235
Total Forecasts	1235
Resolution	60 minutes
First initial time	2009-01-01T00:00:00
Last initial time	2009-12-29T00:00:00
Horizon	48
Interval	1440 minutes
Forecast window count	363

- BANC
- CIPB
- CIPV
- TIDC
- Hydro

