

Hybrid Energy System to H₂ to Green Steel/Ammonia

Jennifer King and Steve Hammond
National Renewable Energy Laboratory
DOE Contract # or WBS #
June 6, 2023

DOE Hydrogen Program
2023 Annual Merit Review and Peer Evaluation Meeting

Project ID: SDI001a

Project Goal

- **Vision:** Develop a national roadmap and reference designs for GW-scale off-grid, tightly-coupled, hybrid energy systems purpose-built for green H₂ production, in close proximity to or co-located with industry end uses, that can accelerate the path to decarbonization for hard to abate industries.
- **Project Goal:** design and analyze tightly-coupled systems to significantly lower costs for green steel and green ammonia
 - Develop initial cost projections for integrated, wind-H₂ design for GW-scale system at four diverse locations.
 - Compare off-grid approach to steam methane reforming (SMR) and grid-connected designs.
 - Calculate life cycle Greenhouse Gas (GHG) emissions.

Overview: Timeline and Budget

Outcomes:

- Phase 0: Market analysis (August-September 2022)
- Phase 1: Analysis for tightly-coupled, co-located green steel/ammonia systems (October 2022 – April 2023)
- Phase 2: Reference designs for green steel and ammonia (April 2023 – April 2024)

Timeline and Budget

- Project Start Date: 8/1/2022
- FY22 DOE Funding (if applicable): \$2.5M
- FY23 Planned DOE Funding (if applicable): \$3M
- Total DOE Funds Received to Date**: \$2.5M
 - ** Since the project started

Overview: Barriers and Targets

Technical Barriers

- Design and analyze shared components across renewable power, hydrogen, and steel/ammonia
- Integrate tools developed in isolation for individual technologies into one framework to exploit synergies across technologies

Technical Targets

- Targeting systems that reduce costs 10-20%+ due to tight-coupling and co-locating technologies

Five-lab Partnership:

- Project co-leads: Jennifer King and Steve Hammond, **NREL**
- Hanna Breunig/**LBNL**, Pingping Sun/**ANL**, Brian Ehrhart/**SNL**, Joao Pereira Pinto/**ORNL**

Overview: Core Research Questions/Key Insights

Are integrated, tightly coupled, decentralized, near-located, non-grid connected [“Integrated H2”], wind-H2-green steel/ammonia designs:

- **Viable and demonstrable** in the immediate, near-term,
- **Enable substantial, rapid H2 deployment**, and are they
- Substantially more **cost effective**

therefore, **enabling significantly more industrial systems-wide GHG reductions** with substantially more rapid deployment than

- Existing fossil SMR-CCUS
- Advanced nuclear/small modular reactors
- Existing siloed grid-H2 pathways (with mixed clean renewable and non-clean electricity generation)?


Potential Impact: Key Insights

Key Insight 1: Hybrid system designs with wind+solar can significantly reduce LCOH costs.

- Solar provides a valuable compliment in suboptimal wind resource areas
- Reducing storage requirements and increasing utilization of electrolyzer

Key Insight 2: IRA policy is a game changer for Integrated H2.

- More cost effective than FE-CCUS, advanced nuclear and siloed systems.
- Integrated H2 will fully qualify for the full clean H2 \$3/kg credit and wind/Solar can take direct advantage of the full PTC & ITC credits.
- Integrated H2 highly likely to fully satisfy ALL additionality and hourly time matching requirements.



Potential Impact: Key Insights

Key Insight 3: “Integrated H2” costs are highly site specific.

- Diverse **wind resource have a substantial impact on LCOE and therefore LCOH.**
- Off-grid deployment enables massive numbers of potential new locations for integrated H2 deployment at these lower costs, independent of new transmission builds.

Key Insight 4: Costs of H2 storage is a big driver for LCOH-Delivered

- If steady-state end use is required or if storage is needed to buffer between renewable generation and end use for extreme weather events.
- Co-location is key because it avoids the cost of pipelines.

Key Insight 5: Directly coupling renewables to hydrogen can provide a significant cost savings and can accelerate scalability and cost effectiveness.

Potential Impact

Potential Impact: Current grid expansion requirements for new, incremental interconnection capacity, intra-regional transmission and inter-regional transmission to serve demands for:

- A. 100% clean grid conversion by 2035, and
- B. Direct Electrification for EVs and Heat Pumps -- are massive and far exceed any historical grid installation levels.

Current transmission development typically takes 5-10+ years to build and currently does not have the grid policies or grid financial incentives needed to reduce this build time period.


Serving grid additionality/expansion capacity for Wind-H2-Green Steel/Ammonia type applications will be low priority and are unlikely.

Integrated H2 provides an accelerated deployment pathway.

Approach: Use Case Configurations


1

Fossil-H₂-Steel/Ammonia Production (with CCS option)




2

Grid Connected H₂ Production co-located Steel/Ammonia



3


Integrated H₂, Off-grid production co-located with Steel/Ammonia



Determine the cost savings and potential advantages to off-grid, tightly coupled wind-H₂-industrial end uses

Approach: Four Land-based Locations for Phase I

- Steel and ammonia production are primarily in central U.S.
- Selected initial four central locations for analysis, with various attributes



IOWA

- Existing ammonia pipeline
- Close to ammonia and steel demand centers
- No geologic storage

INDIANA


- Largest steel mill in the U.S. with 8.2 MMT steel/year capacity
- No geologic storage

TEXAS

- Salt caverns and water stress region
- Excellent wind resources

MISSISSIPPI

- Close to existing demand
- Salt caverns




Accomplishments: Delivered LCOH in Best Location Analyzed Texas, TY 2030

Dependent on electricity price. This plot includes retail rates at 8.6 cents/kWh

PTC credit considered but CCS credit is the more lucrative credit in the best-case scenario

Off-grid costs less than on-grid:

- Reduced electricity costs (retail vs. dedicated PPA results in decrease)
- Dynamic operation of H2 allowed (and accounted for in increased replacement costs)
- Low-cost hydrogen storage (salt caverns)



*Distributed includes electrical efficiency gains ~4%

*Conversion efficiencies are not included in this slide, addressed in backup (only applies to centralized case)





Notes:

- Technology year (TY) 2030 corresponds to operational year 2035
- CCS credit considered for over 12 years
- H2/wind PTC applied over 10 years
- Model does not account for RECs
- **LCOE for TX 2030**
 - Off-grid: 1.3 cents/kWh with PTC
 - On-grid: 8.6 cents/kWh (retail rates), 4.1 cents/kWh (wholesale rates)

Co-located renewables + electrolyzer backfilled with grid electricity


Key Insight:
IRA can be a significant driver for integrated LCOH

Accomplishments: LCOS and LCOA cost competitive with SMR with and without policy



Accomplishments: Steel and Ammonia with Wind-Solar Hybrids, **No Policy**

2030, Off-Grid, No policy, Basic Electrolyzer Control




Key Insight:
Hybrids have significant impact on LCOH

Additional Takeaways

1. LCOH is reduced by up to 35%
2. LCOS is reduced by up to 17%
3. LCOA is reduced by up to 35% (mostly driven by LCOH)

Accomplishments: Steel and Ammonia with Wind-Solar Hybrids, **Maximum Policy**

2030, Off-Grid, Max policy, Basic Electrolyzer Control




Key Insight:
With max policy, all locations compete with SMR

- Additional Takeaways**
1. Adding max policy makes **hydrogen cost competitive in all locations** by 2030
 2. Steel and ammonia are competitive in all locations

Accomplishments: Best and Worst GHG Emission Intensity Scenarios

- Assuming 95% carbon capture for SMR + CCS process and 95% clean grid by 2035
- Best case scenario is for Texas in 2035, off grid case
- Worst case scenario is for Mississippi in 2020, grid-only case
- Infrastructure embedded emissions result in GHG ~ 0.5 kg CO₂e/kg H₂
- Maximum potential reductions amount for over 97% from worst to best case scenario



Collaboration and Coordination

- Collaboration has been a key to achieving our projects goals.
- Lab collaborators include:
 - **LBNL (sub)** – steel TEA model and inputs on hydrogen storage technologies
 - **ANL (sub)** – GREET for LCA and ammonia modeling
 - **ORNL (sub)** – power electronics design and performance for different configurations of wind and electrolyzers.
 - **SNL (sub)** – to come – safety, codes, and standards necessary to realize green steel and green ammonia
- **University collaborator:** Arizona State University (Sridhar Seetharaman)
 - Advise on green steel process and promising integration pathways



Coordination with Key Stakeholders


- Market analysis covering multiple stakeholders to map gaps and tools needed to accelerate industrial decarbonization
 - Database of tools, data, and demonstrations on green steel/ammonia compiled
 - Ensure this project is market relevant and has path to industry impact
- Coordinated with other projects including H2@Scale, H2NEW, DECARB, HyMARC, etc.

Remaining Challenges and Barriers

- **Challenges:**

- Producing realistic reference designs with enough granularity to pursue tightly coupled systems
- Need to understand the national impact of off-grid systems
- Demonstrating the value of tightly or directly coupled systems
- Understanding the safety challenges with these novel designs

Proposed Future Work



Proposed future work depends on budgets and is subject to change.

Summary

- **Hybrid system designs with wind+solar can significantly reduce LCOH costs.**
- **IRA policy is a game changer for Integrated H2.**
- “Integrated H2” costs are highly site specific.
- **Costs of H2 storage is a big driver for LCOH-Delivered**
- **Directly coupling renewables to hydrogen can provide a significant cost**

Integrated, tightly coupled, decentralized, near-located, non-grid connected [“Integrated H2”], wind-H2-green steel/ammonia designs have the potential to **enable significantly more industrial systems-wide GHG reductions** with greatly accelerated deployment

Thank You

www.nrel.gov

This work was authored in part by the National Renewable Energy Laboratory, operated by Alliance for Sustainable Energy, LLC, for the U.S. Department of Energy (DOE) under Contract No. DE-AC36-08GO28308. Funding provided by U.S. Department of Energy Office of Energy Efficiency and Renewable Energy Hydrogen and Fuel Cell Technologies Office. The views expressed in the article do not necessarily represent the views of the DOE or the U.S. Government. The U.S. Government retains and the publisher, by accepting the article for publication, acknowledges that the U.S. Government retains a nonexclusive, paid-up, irrevocable, worldwide license to publish or reproduce the published form of this work, or allow others to do so, for U.S. Government purposes.



Technical Backup and Additional Information

(Include this “divider” slide before your technical backup slides [maximum 20]. These technical backup slides will be available for oral presenters to use for Q&A and will be included in the published web PDFs for oral and poster presentations.

*Note there is **one required slide** in this section and several suggested slides.)*

Project Plan

PROJECT PHASES

PHASE 1: General Design, Model Integration, Initial TEA/LCA Assessments

PHASE 2: Detailed system design/analysis, demo concepts

PHASE 3: Demonstration

ACTIVITIES AND GOALS


- Initial end-to-end integrated analysis for renewables-H2-steel/ammonia in an Initial Project Sprint
- Investigate possible advantages to off-grid, tightly coupled GW-scale wind-H2 production for steel/ammonia end uses



- National roadmap + location-specific reference designs
- Detailed system design and control from power electronics to storage technologies to product delivery
- Design possible 10 MW Green Steel Demo at NREL's ARIES



- 10 MW hardware integrated research and demonstration platform at ARIES
- GW-scale emulation of the end-to-end system at ARIES including renewables-H2-steel/ammonia



Phase 1 Focus Areas

- Preliminary **design and cost analysis**
 - Investigate advantages of integrated, **renewables-H₂** for GW-scale system at four diverse locations
 - Compare to steam methane reforming (SMR) and siloed utility electricity-based designs.
 - Calculate life cycle Greenhouse Gas (GHG) emissions (no updates from phase 1a)
- Create **integrated software modeling capability**:
 - Integrated, co-located, off-grid **renewables-H₂** system
 - Integrating diverse multi-lab sub-component tools
- **Market survey** to assess industry status, pain points, directions, and future needs
- **Explore ~10 MW scale demonstration concepts** at NREL Flatirons, that can be basis for wide range of research innovations and actual, on-site operations and production of green steel/ammonia

Core Research Questions/Key Insights

Are integrated, tightly coupled, decentralized, near-located, non-grid connected [“Integrated H2”], wind-H2-green steel/ammonia designs:

- **Viable and demonstrable** in the immediate, near-term,
- **Enable substantial, rapid H2 deployment**, and are they
- Substantially more **cost effective**

therefore, **enabling significantly more industrial systems-wide GHG reductions** with substantially more rapid deployment than

- Existing fossil SMR-CCUS
- Advanced nuclear/small modular reactors
- Existing siloed grid-H2 pathways (with mixed clean renewable and non-clean electricity generation)?

PHASE 1 Modeling and Analysis Key Insights- Viable and Demonstrable

Key Insight 1: Decentralized designs are viable but not substantially beneficial for LBW/Hybrids in deployment scalability or cost effectiveness.

- Off-setting benefits and costs for electrolyzers directly coupled with wind turbines.
- Electrical efficiency gains are around 1-4%.
- Ex: shared power electronics and cabling vs. pipelines are not enough to offset cost of smaller electrolyzers and current O&M costs

Key Insight 2: Full end-to-end demonstration of integrated H2 at NREL ARIES is viable and substantially underway.

- Wind Modern Turbine acquisition is underway,
- PV solar, batteries/other electricity storage, and integrated control via CGI are currently deployed and being expanded;
- these components along with on-site PEM H2 production capabilities, plus planned H2 Storage, plus potential award for on-site steel production (“SHREC” AMMTO proposal) would enable a full end-to-end demonstration and research platform.

PHASE 1 Modeling and Analysis Key Insights


Cost Effective

Key Insight 3: “Integrated H2” costs are highly site specific.

- Diverse **wind resource** have a **substantial impact on LCOE and therefore LCOH**.
- Off-grid deployment enables massive numbers of potential new locations for integrated H2 deployment at these lower costs, independent of new transmission builds.

Key Insight 4: Costs of H2 storage is a big driver for LCOH-Delivered

- If steady-state end use is required or if storage is needed to buffer between renewable generation and end use for extreme weather events.
- Integrated H2 also significantly reduces requirements/dependencies for a nationwide H2 pipeline backbone – accelerating deployment.



PHASE 1 Modeling and Analysis Key Insights

Cost Effective

Key Insight 5: Hybrid system designs with wind plus solar can significantly reduce LCOH costs.

- Solar provides a valuable compliment in suboptimal wind resource areas
- Reducing storage requirements and increasing utilization of electrolyzer

Key Insight 6: Electrolyzer degradation under dynamic operations has a small impact on LCOH, especially as electrolyzer costs are reduced over time.

Key Insight 7: IRA policy is a game changer for Integrated H2.

- More cost effective than FE-CCUS, advanced nuclear and siloed systems.
- Integrated H2 will fully qualify for the full clean H2 \$3/kg credit and wind/Solar can take direct advantage of the full PTC & ITC credits.
- Integrated H2 highly likely to fully satisfy ALL additionality and hourly time matching requirements.

“Integrated H2” supports rapid H2 deployment

Observation: Current grid expansion requirements for new, incremental interconnection capacity, intra-regional transmission and inter-regional transmission to serve demands for:

- A. 100% clean grid conversion by 2035, and
- B. Direct Electrification for EVs and Heat Pumps -- are massive and far exceed any historical grid installation levels.

Current transmission development typically takes 5-10+ years to build and currently does not have the grid policies or grid financial incentives needed to reduce this build time period.

Serving grid additionality/expansion capacity for Wind-H2-Green Steel/Ammonia type applications will be low priority and are unlikely.

Integrated H2 provides an accelerated deployment pathway.

Phase 1a (December Briefing)

- **End-to-end modeling capability:**
 - renewable generation technologies (wind and solar),
 - hydrogen production technologies (PEM),
 - hydrogen storage technologies (salt caverns, lined rock caverns, compressed gas, and plans to include hydrogen carriers in Phase 2),
 - end uses (steel and ammonia).
 - On and off-grid configurations compared with SMR
 - *This code is modular and can be adapted to other technologies in this workflow. Leveraged from H2OPP.
- **Spatially correlated data at high resolution:** all data is spatially correlated at 2km resolution to increase accuracy
 - Wind, solar, storage, BOS costs
 - Raw material costs
 - Water, land, etc.
- **Capex/opex savings addressed**
 - pipeline vs. cabling, BOS savings
 - shared power electronics
 - **Projected gains: 1-3%**
- **Policy included makes LCOH cost competitive with SMR**


Phase 1b Focus Areas

- **Increased Capacity Factor:** Phase 1a had wind-only
 - Phase 1b added solar and battery to hybrid system
 - This increases electrolyzer utilization and lifetime, minimizes start/stop, decreases variability.
 - **Result: 1-35% LCOH savings** (dependent on location, mostly beneficial in MS, IA, IN)
- **Electrical Efficiencies:**
 - Phase 1a included capex savings,
 - Phase 1b incorporates OpEx electrical efficiency gains from shared power electronics (distributed only)
 - **Result: 1-4% savings on LCOH**
- **Conversion efficiencies:**
 - Phase 1b added advanced controls of electrolyzer stacks (centralized only)
 - This keeps hydrogen production nearly constant and increases the electrolyzer life expectancy.
 - **Result: 1-3% savings on LCOH** (dependent on electrolyzer costs)
- **We have initial offshore results for fixed bottom (floating under development) in the backup section.**
- *Outside project scope:* nuclear, fossil energy, or CSP. These technologies could be included in future. Focused on production of electricity and fuels; not focused on detailed/optimized methods for heat integration.

Review: Use Case Configurations


1

Fossil-H₂-Steel/Ammonia Production (with CCS option)




2

Grid Connected H₂ Production co-located Steel/Ammonia



3

Integrated, Off-grid H₂ Production with co-located Steel/Ammonia



Determine the cost savings and potential advantages to off-grid, tightly coupled wind-H₂-industrial end uses

Electrolyzer cost assumptions are determined from literature and HFTO targets

- Costs and credits amortized over 30-year useful lifetime
- Electrolyzer uninstalled system costs are based on literature and HFTO targets
 - Electrolyzer component costs for 2020 taken from EU-funded study^[1]; system cost roughly matches HFTO 2022 status of \$1,000/kW
 - Low-cost case:
 - Future electrolyzer system costs taken from HFTO targets
 - Distributed system costs calculated using scaling factors from [1]
 - Mid-cost case: future costs calculated using learning rates and estimated future capacities from DOE-funded electrolyzer supply chain report^[2]
- Installation and indirect costs taken from H2A

Uninstalled electrolyzer system capital costs (\$2019/kW)

Technology year	Low-Cost Case		Mid-Cost Case	
	Centralized	Distributed*	Centralized	Distributed*
2020	1114	1403	1114	1403
2025	450	642	827	1096
2030	200	299	372	537
2035	150	228	308	450

*For a 6 MW turbine. Site-specific cost will depend on turbine rating.

Installation and Indirect Costs

Parameter	Value
Installation cost (% of uninstalled manufacturing price)	12%
Site preparation (% of total installed cost)	2%
Engineering and design (% of total installed cost)	10%
Permitting (% of total installed cost)	15%
Project contingency (% of total installed cost)	15%

[1] Bohm et al. Applied Energy 264 (2020), 114780.

[2] Badgett et al. "Water Electrolyzers and Fuel Cells Supply Chain: Supply Chain Deep Dive Assessment." February 2022

Other Key Assumptions

- Costs and credits amortized over 30-year useful lifetime
- Initial analysis uses detailed wind and solar models, **costs vary spatially and temporally**, e.g. →

Year	IN	TX	IA	MS	WY
2020	1420	1420	1709	2232	1420
2025	1210	1210	1542	1938	1210
2030	1000	1000	1374	1644	1000
2035	986	986	1348	1613	986

- Natural gas cost** used for default scenarios is **\$5.64/MMBTU** (min: \$2.53/MMBTU, max: \$11.50/MMBTU)
- Steel & ammonia operated in steady state, sufficient H₂ storage for continuous operation
- Retail rates used for on-grid scenarios – location-specific based on AEO and Cambium database (ReEDS 2021 scenarios)



- H₂ storage installed costs:

Storage Type	Storage Cost (\$/kg-H ₂)
Salt cavern	17
Lined-rock cavern	43
Pressure vessel	525

- Compression cost of \$39/kW captured separately in the modeling framework

TEA on Five Land-based Locations for Phase I

- Steel and ammonia production are primarily in central U.S.
- Selected initial four central locations for analysis, with various attributes



IOWA

- Existing ammonia pipeline
- Close to ammonia and steel demand centers
- No geologic storage

INDIANA

- Largest steel mill in the U.S. with 8.2 MMT steel/year capacity
- No geologic storage

TEXAS

- Salt caverns and water stress region
- Excellent wind resources

MISSISSIPPI

- Close to existing demand
- Salt caverns

WYOMING

- Best wind resource in the country
- Ammonia production nearby


High Level Insights/Trends

reV Team

Owen Roberts, Travis Williams, Paul Pinchuk

Hybrid System - Levelized Cost of Hydrogen

ATB Advanced
1 to 1 Solar/Wind Capacity*
1 to 1 Capacity/Electrolyzer Ratio
Standard Costs
No Pipeline/Storage




Hybrid System - Least-Cost Systems

ATB Advanced
All Solar/Wind Capacities*
System-specific Capacity/Electrolyzer Ratios
Standard Costs
No Pipeline/Storage

System Design


- Hybrid, 1 to 1 Wind/Solar, Electrolyzer Ratio 0.5
- Hybrid, 1 to 2 Wind/Solar, Electrolyzer Ratio 0.5
- Hybrid, 2 to 1 Wind/Solar, Electrolyzer Ratio 0.5
- Solar, Electrolyzer Size Ratio 0.9
- Wind, Electrolyzer Size Ratio 0.9




Annual Hydrogen Production Potential - No Pipelines

Hybrid Wind/Solar, 1:1 Capacity Ratio
ATB Advanced
Electrolyzer Ratio 0.5
30 year lifetime

Under \$2/kg




Under \$3/kg




Annual Hydrogen Production Potential - With Pipelines

Hybrid Wind/Solar, 1:1 Capacity Ratio
ATB Advanced
Electrolyzer Ratio 0.5

Under \$2/kg



Under \$3/kg



Key Takeaways – High Level

- Hybrid wind-solar PV H₂ systems **reduce LCOH for over 5 TW** of technical potential relative to wind only systems. Assumes 1:1 ratio of wind/PV capacity
- Pipeline use or capacity factor, resource complementarity, and total system cost **drive hybrid cost effectiveness**
- **Reducing or eliminating pipeline costs** increases ECR value resulting in minimum LCOH
- **On site generation applications will likely produce lower LCOH values** with higher ECR values than pipeline connected H₂ systems
- Wind generation profile, specific power, and **resource have a large influence** in ideal electrolyzer capacity
- **Lower resource sites result in lower ECR values** due to less wind energy generation at or near rated power
- **High resource sites result in higher ECR values** due to higher energy generation fraction from greater time at rated power
- Sites with LCOH values **<\$2/kg show little potential to reduce LCOH by hybridizing**; Some significant exceptions in TX, interestingly at high wind CF sites

Detailed View in 5 Locations


Recall: Delivered LCOH in Best Location Analyzed: Texas, TY 2030

Dependent on electricity price. This plot includes retail rates at 8.6 cents/kWh

PTC credit considered but CCS credit is the more lucrative credit in the best-case scenario

Off-grid costs less than on-grid:

- Reduced electricity costs (retail vs. dedicated PPA results in decrease)
- Dynamic operation of H2 allowed (and accounted for in increased replacement costs)
- Low-cost hydrogen storage (salt caverns)



*Distributed includes electrical efficiency gains ~4%

*Conversion efficiencies are not included in this slide, addressed in backup (only applies to centralized case)





Co-located renewables + electrolyzer backfilled with grid electricity

Key Insight #7:
With max policy, all locations compete with SMR


Notes:

- Technology year (TY) 2030 corresponds to operational year 2035
- CCS credit considered for over 12 years
- H2/wind PTC applied over 10 years
- Model does not account for RECs
- **LCOE for TX 2030**
 - Off-grid: 1.3 cents/kWh with PTC
 - On-grid: 8.6 cents/kWh (retail rates), 4.1 cents/kWh (wholesale rates)

LCOS and LCOA cost competitive with SMR with and without policy




Wind-only (centralized): Locations with geologic storage and excellent wind resource perform best



Sensitivity to Storage Capacity Viable for Salt Caverns and Prohibitive for PVS

2030, Centralized, Off-Grid, Wind, No policy, Basic Electrolyzer Control




Key Insight #4:
Low-cost hydrogen storage is critical

Additional Takeaways

- Adding 50% more storage increases LCOH in all cases.
- Most notably in IA and IN where salt caverns are not accessible.
- Type of storage has a significant impact.

Opportunity space for material storage


Courtesy of LBNL
Hanna Breunig



- Storage cannot cost more than 4x salt caverns to compete with SMR + CCS or 5.3x for SMR
- This also applies to salt caverns deviating from base assumed cost value, which is uncertain.
- Policy credit is key
- Off-grid tends to look better than grid connected
- Closely coupling renewables and electrolyzers offers savings but there are other factors that impact costs more (like storage)

Adding Solar to Wind Can Decrease LCOH Significantly

2030, Off-Grid, No policy, Basic Electrolyzer Control




Key Insight #5:
Hybrids have significant impact on LCOH

Additional Takeaways

1. Reduce LCOH by 35%
2. Improve CF of PEM by up to 30%
3. Significantly improve lifetime of PEM
4. Reduce hydrogen storage duration by half in some cases.

Steel and Ammonia with Wind-Solar Hybrids, No Policy

2030, Off-Grid, No policy, Basic Electrolyzer Control




Key Insight #5:
Hybrids have significant impact on LCOH

- Additional Takeaways**
1. LCOH is reduced by up to 35%
 2. LCOS is reduced by up to 17%
 3. LCOA is reduced by up to 35% (mostly driven by LCOH)

Steel and Ammonia with Wind-Solar Hybrids, Maximum Policy

2030, Off-Grid, Max policy, Basic Electrolyzer Control




Key Insight #7:
With max policy, all locations compete with SMR

- Additional Takeaways**
1. Adding max policy makes **hydrogen cost competitive in all locations** by 2030
 2. Steel and ammonia are competitive in all locations

Does Degradation Impact LCOH?

2020, Centralized, Off-Grid, Wind, No policy, Basic Electrolyzer Control




Key Insight #6:
Impact of degradation is smaller than expected

- Additional Takeaways:**
- H2A assumption for stack replacements cost is 15% of capex.
 - Improvements to lifetime do not significantly impact LCOH (~12% reduction possible).

Does Degradation Impact LCOH?

2030, Centralized, Off-Grid, Wind, No policy, Basic Electrolyzer Control



Key Insight #6:
Impact of degradation
is smaller than
expected

Additional Takeaways:

- Degradation *minimally* impacts LCOH when using super aggressive electrolyzer costs (\$200/kW).
- H2A assumption for stack replacements cost is 15% of capex.

Technology Transfer Activities

- Software record submitted
- Energy I-Corps being pursued
- Future fundings: IEDO, OCED, Industry partners being pursued
- Marketing strategies:
 - We hope to leverage and learn effective strategies through Energy I-Corps.

Special Recognitions and Awards

- N/A

Publications and Presentations

- Draft manuscript to Joule in preparation on Phase 1 results
- Webinars on offshore wind and energy storage and renewable hydrogen